

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	16295	Contact Number	
Facility Name	Ameco	Contact email	
Address	1643 Prairie Ave, South Bend	Date of Inspection	04-26-25
Operator on Duty Name	Sh-46613	Name of the Person Conducting Inspection	Madon Singh

Operator Training		Registration/Notification Form		Release Detection	
Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Release Detection Method	☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No	Make and Model	VR-TLS350
Does it have paper?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No	Is it in Alarm mode?	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No	Necessary Monthly Printout Taken	☒ Yes ☐ No

Spill Buckets		Fill Ports		Piping/STP Sumps		Under Dispenser Containments (UDC)	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No	Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No	Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No	NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			

Operator on Duty Name	Signature	Date
-----------------------	-----------	------

317-645-0215

tanksdata@gmail.com

www.tanksdata.com