



30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	16225	Contact Number	
Facility Name	AMOCO	Contact email	
Address	1643 Prairie Ave 98013	Date of Inspection	06-27-2025
Operator on Duty Name		Name of the Person Conducting Inspection	Couper

Operator Training current	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ CIM	☐ SIR ☐ IC ☐ Other	
Make and Model	UR TCS-350	Operator Notified	☐ Yes ☐ No
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

06-27-2025
www.tanksdata.com