

PO BOX 335
CORYDON, IN 47112
812-946-6547
AJPETROLEUM@AOL.COM



A&J PETROLEUM

STP Sump Hydro Test Results

Tank	1	2	3	4	5
Product	UNL	PREM			
Test Start Time	1400	1400			
Initial Reading (in)	24in	24in			
Test End Time	1500	1500			
Final Reading (in)	24in	24in			
Water Loss (in)	0	0			
Pass(P) or Fail(F)	P	P			

Please accept the above results with full confidence. Any questions or concerns with regards to the results or methods used should be directed to AJPETROLEUM@AOL.COM

John Ellett
UC2001KY866687