

PL EXPO 4
1643 PRAIRIE AVE
SOUTH BEND, IN 46613

JUL 29, 2025 7:10 PM

CSLD TEST RESULTS

JUL 29, 2025 7:10 PM

T 1:UNL
PROBE SERIAL NUM 225703

0.2 GAL/HR TEST
PER: JUL 29, 2025 PASS

T 2:PREM
PROBE SERIAL NUM 128151

0.2 GAL/HR TEST
PER: JUL 29, 2025 PASS

* * * * * END * * * * *

PL EXPO 4
1643 PRAIRIE AVE
SOUTH BEND, IN 46613

JUL 29, 2025 7:10 PM

LIQUID STATUS

JUL 29, 2025 7:10 PM

L 1:UNL STP
SENSOR NORMAL

L 2:PREM STP
SENSOR NORMAL

L 3:INT
FUEL ALARM

* * * * * END * * * * *