

Columbus 2 Food Mart
FID 239
3350 Jonathan Moore Pike
Columbus IN 47201
07/28/2025 12:41:19

SENSOR REPORT
Last Available

2 WIRE SENSOR

No Records Found

3 WIRE SENSOR

Unleaded Sump Sensor
Ok
07/28/2025 12:41:19

Premium Sump Sensor
Sensor On
07/28/2025 12:41:19

Diesel Sump Sensor
Sensor On
07/28/2025 12:41:19

Unleaded Interstitial
Sensor
Ok
07/28/2025 12:41:19

PREM/DSL Interstitial
Sensor
Ok
07/28/2025 12:41:19

MAG SENSOR

No Records Found

Columbus 2 Food Mart
FID 239
3350 Jonathan Moore Pike
Columbus IN 47201
07/28/2025 12:41:24

REGULATORY REPORT
(Passed Tests)
July 2025

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope

▶ 07/27/2025 04:57:29 0.06
⊗ 07/27/2025 06:30:52

Slope
▶ 07/05/2025 20:04:57 0.05
⊗ 07/06/2025 05:25:53

Tank 2
Premium
SCALD
Slope

▶ 07/11/2025 06:29:25 0.03
⊗ 07/11/2025 08:36:31

Slope
▶ 07/03/2025 00:43:56 -0.04
⊗ 07/03/2025 02:09:35

Tank 3
Diesel
SCALD
Slope

▶ 07/27/2025 01:56:04 -0.02
⊗ 07/27/2025 06:32:20

3 WIRE SENSOR (MONTHLY)

Unleaded Sump Sensor
07/28/2025 12:00:00
07/08/2025 12:00:00

Unleaded Interstitial Se
07/28/2025 12:00:00

PREM/DSL Interstitial Se
07/28/2025 12:00:00