

AUTOMATIC TANK GAUGE FUNCTIONALITY TEST

Facility Name:	Food Mart Marathon
Address:	3350 W Jonathan Moore Pike
City, State, Zip Code:	Columbus, IN 47201
Facility I.D. #:	239

Owner:	Food Mart Marathon
Address:	3350 W Jonathan Moore Pike
City, State, Zip Code:	Columbus, IN 47201
Phone #:	

This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

Tank Number	1	2	3		
Product Stored	Regular	Premium	Diesel		
ATG Brand and Model	TS 550 EVO	TS 550 EVO	TS 550 EVO		
1. Tank Volume, gallons	15,041	6,044	3,765		
2. Tank Diameter, inches	120	96	96		
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	Yes ☐	Yes ☐	Yes ☐		
4. Float moves freely on the stem without binding?	Yes ☐	Yes ☐	Yes ☐		
5. Fuel float level agrees with the value programmed into the console?	Yes ☐	Yes ☐	Yes ☐		
6. Water float level agrees with the value programmed into the console?	Yes ☐	Yes ☐	Yes ☐		
7. Inch level from bottom of stem when 90% alarm is triggered.	104	81	81		
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	Yes ☐	Yes ☐	Yes ☐		
9. Inch level from the bottom when the water float first triggers an alarm.	2	2	2		
10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge?	Yes ☐	Yes ☐	Yes ☐		
If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.					
Test Results	Pass ☐	Pass ☐	Pass ☐		

Comment:

Tester's Name : Josh Rider

Tester's Signature : 