



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

7/11/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 239
Address	3350 W Jonathan Moore Pike
City	Columbus
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		
Dies	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	38	22	180 ml	189ml	2 sec	Pass
2	Premium	31	24	150 ml	189ml	2 sec	Pass
3	Diesel	34	24	160 ml	189ml	2 sec	Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :