

Columbus 2 Food Mart
FID 239
3350 Jonathan Moore Pike
Columbus IN 47201
09/26/2025 07:17:04
REGULATORY REPORT
(Passed Test)
September 2025

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope
* 09/25/2025 02:35:14 -0.07
* 09/25/2025 04:01:47 -0.02
Slope
* 09/03/2025 01:45:31 -0.01
* 09/03/2025 03:11:44 -0.03

Tank 2
Premium
SCALD
Slope
* 09/24/2025 21:32:13 -0.03
* 09/25/2025 02:30:15 -0.01
Slope
* 09/12/2025 02:18:34 -0.01
* 09/12/2025 03:44:26 -0.04

Tank 3
Diesel
SCALD
Slope
* 09/26/2025 04:50:18 0.04
* 09/26/2025 06:15:56 0.04

3 WIRE SENSOR (MONTHLY)

Unleaded Sump Sensor
09/25/2025 12:00:00
09/04/2025 12:00:00

Unleaded Interstitial Se
09/25/2025 12:00:00
09/24/2025 12:00:00

PREM/DSL Interstitial Se
09/25/2025 12:00:00
09/24/2025 12:00:00
.....

Columbus 2 Food Mart
FID 239
3350 Jonathan Moore Pike
Columbus IN 47201
09/26/2025 07:17:10

SENSOR REPORT Last Available

2 WIRE SENSOR

No Records Found

3 WIRE SENSOR

Unleaded Sump Sensor
Ok
09/26/2025 07:17:10

Premium Sump Sensor
Sensor On
09/26/2025 07:17:10

Diesel Sump Sensor
Sensor On
09/26/2025 07:17:10

Unleaded Interstitial
Sensor
Ok
09/26/2025 07:17:10

PREM/DSL Interstitial
Sensor
Ok
09/26/2025 07:17:10

MAG SENSOR

No Records Found

Columbus 2 Food Mart
FID 239
3350 Jonathan Moore Pike
Columbus IN 47201
09/26/2025 07:17:11

SCALD REPORT Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 15,041.0

Begin End
09/25/2025 09/25/2025
02:35:14 04:01:47
Result Pass
Slope -0.07
Status 0
Volume Qualify(%) 14

Premium
Premium
Capacity: 6,044.0

Begin End
09/24/2025 09/25/2025
21:32:13 02:30:15
Result Pass
Slope -0.03
Status 0
Volume Qualify(%) 14

Diesel
Diesel
Capacity: 3,765.0

Begin End
09/26/2025 09/26/2025
04:50:18 06:15:56
Result Pass
Slope 0.04
Status 0
Volume Qualify(%) 14