

CROTHERSVILLE MARATH
417 ARMSTRONG ST
CROTHERSVILLE, IN.

OCT 13, 2025 12:04 PM

CSLD TEST RESULTS

OCT 13, 2025 12:04 PM

T 1:UNLEADED
PROBE SERIAL NUM 843863

0.2 GAL/HR TEST
PER: OCT 13, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 844748

0.2 GAL/HR TEST
PER: OCT 13, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 843877

0.2 GAL/HR TEST
PER: OCT 13, 2025 PASS

* * * * * END * * * * *

CROTHERSVILLE MARATH
417 ARMSTRONG ST
CROTHERSVILLE, IN.

OCT 13, 2025 12:04 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 843863

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CROTHERSVILLE MARATH
417 ARMSTRONG ST
CROTHERSVILLE, IN.

OCT 13, 2025 12:05 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 844748

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CROTHERSVILLE MARATH
417 ARMSTRONG ST
CROTHERSVILLE, IN.

OCT 13, 2025 12:05 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 843877

NO TEST DATA AVAILABLE

* * * * * END * * * * *