

SALEM SUNOCO
306 N MAIN ST
SALEM IN 47167
812 883 6548

OCT 13. 2025 8:45
OBLD TEST RESULTS
OCT 13. 2025 8:45

T 1:UNLEADED 1
T 2:UNLEADED 2
PROBE SERIAL NUM 231155
0.2 GAL/HR TEST
PER: OCT 13. 2025 PASS

T 3:PREMIUM
PROBE SERIAL NUM 231032
0.2 GAL/HR TEST
PER: OCT 13. 2025 PASS

T 4:DIESEL
PROBE SERIAL NUM 241201
0.2 GAL/HR TEST
PER: OCT 13. 2025 PASS

* * * * * END * * * * *

SALEM SUNOCO
306 N MAIN ST
SALEM IN 47167
812 883 6548

OCT 13. 2025 8:45
PRESSURE LINE LEAK
TEST RESULTS

Q 1:UNLEADED

3.0 GAL/HR RESULTS:

LAST TEST:
OCT 13. 2025 8:35 PASS

NUMBER OF TESTS PASSED 97
PREV 24 HOURS : 28
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

APR	1.	2020	22:56	PASS
MAR	28.	2020	5:15	PASS
MAR	22.	2020	2:08	PASS
MAR	16.	2020	5:29	PASS
MAR	10.	2020	23:41	PASS
MAR	4.	2020	5:49	PASS
FEB	27.	2020	1:04	PASS
FEB	19.	2020	23:19	PASS
FEB	15.	2020	4:01	PASS
FEB	9.	2020	23:26	PASS

0.10 GAL/HR RESULTS:

OCT	16.	2019	21:38	PASS
FEB	2.	2019	4:07	PASS
AUG	3.	2018	13:57	PASS
APR	8.	2015	19:29	PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
OCT 13. 2025 8:33 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 39
SINCE MIDNIGHT : 9

0.20 GAL/HR RESULTS:

APR	7.	2020	23:34	PASS
APR	3.	2020	10:16	PASS
MAR	28.	2020	10:03	PASS
MAR	22.	2020	16:54	PASS
MAR	18.	2020	6:46	PASS
MAR	12.	2020	14:23	PASS
MAR	7.	2020	21:43	PASS
FEB	27.	2020	23:38	PASS
FEB	23.	2020	10:55	PASS
FEB	17.	2020	16:46	PASS

0.10 GAL/HR RESULTS:

FEB	7.	2020	12:18	PASS
AUG	7.	2019	22:32	PASS
AUG	7.	2019	22:27	PASS
FEB	4.	2019	22:27	PASS
AUG	3.	2018	14:18	PASS
APR	24.	2015	8:56	PASS

3.0 GAL/HR RESULTS:
LAST TEST:
OCT 13, 2025 8:35 PASS
NUMBER OF TESTS PASSED 97
PREV 24 HOURS : 28
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:
APR 1, 2020 22:56 PASS
MAR 28, 2020 5:15 PASS
MAR 22, 2020 2:08 PASS
MAR 16, 2020 5:29 PASS
MAR 10, 2020 23:41 PASS
FEB 4, 2020 5:49 PASS
FEB 27, 2020 1:04 PASS
FEB 19, 2020 23:19 PASS
FEB 15, 2020 4:01 PASS
FEB 9, 2020 23:26 PASS

0.10 GAL/HR RESULTS:
OCT 16, 2019 21:38 PASS
FEB 2, 2019 4:07 PASS
AUG 3, 2018 13:57 PASS
APR 8, 2015 19:29 PASS

2:PREMIUM
3.0 GAL/HR RESULTS:
LAST TEST:
OCT 13, 2025 8:33 PASS
NUMBER OF TESTS PASSED 39
PREV 24 HOURS : 9
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:
APR 7, 2020 23:34 PASS
APR 3, 2020 10:16 PASS
MAR 28, 2020 10:03 PASS
MAR 22, 2020 16:54 PASS
MAR 18, 2020 6:46 PASS
MAR 12, 2020 14:23 PASS
MAR 7, 2020 21:43 PASS
FEB 27, 2020 23:38 PASS
FEB 23, 2020 10:55 PASS
FEB 17, 2020 16:46 PASS

0.10 GAL/HR RESULTS:
FEB 7, 2020 12:18 PASS
AUG 7, 2019 22:32 PASS
FEB 4, 2019 22:27 PASS
AUG 3, 2018 14:18 PASS
APR 24, 2015 8:56 PASS

3:DIESEL
3.0 GAL/HR RESULTS:
LAST TEST:
OCT 13, 2025 4:40 PASS
NUMBER OF TESTS PASSED 3
PREV 24 HOURS : 1
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:
APR 25, 2020 0:00 PASS
APR 1, 2020 5:21 PASS
MAR 24, 2020 18:42 PASS
MAR 14, 2020 20:48 PASS
MAR 4, 2020 17:33 PASS
MAR 27, 2020 17:53 PASS
FEB 21, 2020 20:27 PASS
FEB 15, 2020 12:14 PASS
FEB 7, 2020 23:03 PASS
FEB 3, 2020 17:26 PASS

0.10 GAL/HR RESULTS:
FEB 7, 2020 23:46 PASS
AUG 5, 2019 8:10 PASS
FEB 3, 2019 1:09 PASS
AUG 3, 2018 17:44 PASS
APR 8, 2015 16:52 PASS

END * * * * *