



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

7/21/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 249
Address	870 S State St
City	North Vernon
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket ELLD		
Prem	Red Jacket ELLD		
Dies	Red Jacket ELLD		
Kero	Red Jacket ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	31	30	690 ml	189ml	2 cycles	Pass
2	Premium	28	26	440 ml	189ml	2 cycles	Pass
3	Diesel	33	32	320 ml	189ml	2 cycles	Pass
4	Kerosene	-	-	-	189ml	-	.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Kerosene line not in use, not enough fuel in tank to have pump turn on. Cannot be tested.

Technician Signature :