



5296 Breakers Way, Carmel, IN 46033

Date

7/21/25

PRODUCT LINE TEST

Test Location Information

Name	FID 249
Address	870 S State St
City	North Vernon
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1	Product Type : Regular				
TIME	DATA	+/-	GPL	RES	GPH
12:55p	84	0	0.0037	0	0
1:10pm	84	0	0.0037	0	0
1:25pm	84	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2	Product Type : Premium				
TIME	DATA	+/-	GPL	RES	GPH
1:45pm	88	0	0.0037	0	0
2:00pm	87	-1	0.0037	.0037	.0148
2:15pm	86	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3	Product Type : Diesel				
TIME	DATA	+/-	GPL	RES	GPH
2:25pm	80	0	0.0037	0	0
2:40pm	79	-1	0.0037	.0037	.0148
2:55pm	79	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4	Product Type : Kerosene				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 7/21/25

PRODUCT LINE TEST

Test Location Information

Name	FID 249
Address	870 S State St
City	North Vernon
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4	Kerosene	.
5		.
6		.

Kerosene line not in use, not enough fuel in tank to have pump turn on. Cannot be tested.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 