



Emergency Stop Operation

Owner Name: GPM		Date: 2/28/25		Work Order #: 229919				
Facility Name: GPM #25305		Facility ID #:						
Address: 26395 SR 2 W		Testing Company: R. W. Mercer Co. Kalamazoo 269-321-2280						
City, State, Zip Code: South Bend, IN 46619		Tester: Curtis Colizzi		Certification #: C35862				
All testing procedures follow the guide lines put forth in PEI/RP1200.								
E-stop Number	1	2	3	4	5	6	7	8
Location	Next to counter							
1. E-stops labeled and located where easily accessible?	Yes							
2. System fully powered and in normal working condition?	Yes							
3. After activating E-Stop, power disconnected from:								
3a. All dispensing devices on all islands?	Yes							
3b. All STPs for all fuel grades?	Yes							
3c. All power, controls and signal circuits associated with the dispensing devices and the STPs? (low voltage disconnect required only after 2003)	Yes							
3d. All other non-intrinsically safe electrical equipment in classified areas surrounding fuel dispensing devices?	Yes							
4. All intrinsically safe electrical equipment remains energized after E-stop activation?	Yes							
5. After testing, E-stop has been reset and site is back to normal operating condition?	Yes							
A "No" to any lines 3a - 3d indicates a test failure.								
Test Results	Pass							
Comments:								

Tester's Name (print): Curtis Colizzi

Tester's Signature: Curtis Colizzi