



Automatic Tank Gauge Operation Inspection

Owner Name:	GPM	Date:	2/28/25	Work Order #:	229919
Facility Name:	GPM #25305	Facility ID #:			
Address:	26395 SR 2 W	Testing Company:	R. W. Mercer Co.	Kalamazoo	269-321-2280
City, State, Zip Code:	South Bend, IN 46619	Tester:	Curtis Colizzi	Certification #:	C35862

All testing procedures follow the guide lines put forth in PEI/RP1200.

Tank Level Monitor Brand: Veeder-Root				Model: 450+				
Configuration, alarm history printed and battery backup tested.			Yes					
Tank Number	1	2	3	4	5	6	7	8
Product Grade	REGULAR	DIESEL	PREMIUM	KERO				
1. Full Volume, gallons	12032	7896	6016	2000				
2. Tank Diameter, inches	96	96	96	64				
3. Remove probe from the tank, it has been inspected and any damaged or missing parts replaced	Yes	Yes	Yes	Yes				
4. Floats move freely on the probe without binding	Yes	Yes	Yes	Yes				
5. Fuel float level agrees with the value programmed into the console	Yes	Yes	Yes	Yes				
6. Water float level agrees with the value programmed into the console	Yes	Yes	Yes	Yes				
7. Inch level from bottom of probe when 90% alarm is triggered	80	80	80	56				
8. Does this level(#7) correspond to the value programmed in ATG	Yes	Yes	Yes	Yes				
9. Inch level from the bottom when water float first triggers alarm	2	2	2	2				
10. Does this level(#9) correspond to the value programmed in ATG	Yes	Yes	Yes	Yes				
If any results from 3, 4, 5 or 6 are "No", the ATG has failed the test.								
Test Results	Pass	Pass	Pass	Pass				

Comments:

Tester's Name (print): Curtis Colizzi

Tester's Signature: Curtis Colizzi