



EZY Chek Systems Line Test

Owner Name:	GPM	Date:	2/28/25	Work Order #:	229919
Facility Name:	GPM #25305	Facility ID#			
Address:	26395 SR 2 W	Testing Company:	R. W. Mercer Co. Kalamazoo	269-321-2280	
City, State, Zip Code:	South Bend, IN 46619	Tester:	Curtis Colizzi	Certification #:	C35862

Product: REGULAR

Pump Pressure 30 psi Applied Pressure: 45 psi

Time	Data	+/-	GPL	Result	GPH
8:30	80	0	0.0037	0	0.0000
8:45	80	0	0.0037	0	0.0000
9:00	80	0	0.0037	0	0.0000

RESULTS Pass

Sump Sensor Test N/A

Product Line Type STP Sump Type

Product: DIESEL

Pump Pressure 30 psi Applied Pressure: 45 psi

Time	Data	+/-	GPL	Result	GPH
8:30	80	0	0.0037	0	0.0000
8:45	78	-2	0.0037	-0.0074	-0.0296
9:00	77	-1	0.0037	-0.0037	-0.0148
9:15	77	0	0.0037	0	0.0000

RESULTS Pass

Sump Sensor Test N/A

Product Line Type STP Sump Type

Product:

Pump Pressure psi Applied Pressure: psi

Time	Data	+/-	GPL	Result	GPH

RESULTS

Sump Sensor Test

Product Line Type STP Sump Type

Product:

Pump Pressure psi Applied Pressure: psi

Time	Data	+/-	GPL	Result	GPH

RESULTS

Sump Sensor Test

Product Line Type STP Sump Type

Product: PREMIUM

Pump Pressure 30 psi Applied Pressure: 45 psi

Time	Data	+/-	GPL	Result	GPH
8:30	70	0	0.0037	0	0.0000
8:45	70	0	0.0037	0	0.0000
9:00	70	0	0.0037	0	0.0000

RESULTS Pass

Sump Sensor Test N/A

Product Line Type STP Sump Type

Product:

Pump Pressure psi Applied Pressure: psi

Time	Data	+/-	GPL	Result	GPH

RESULTS

Sump Sensor Test

Product Line Type STP Sump Type

Product:

Pump Pressure psi Applied Pressure: psi

Time	Data	+/-	GPL	Result	GPH

RESULTS

Sump Sensor Test

Product Line Type STP Sump Type

Product:

Pump Pressure psi Applied Pressure: psi

Time	Data	+/-	GPL	Result	GPH

RESULTS

Sump Sensor Test

Product Line Type STP Sump Type

Comments

Tester's Name (print): Curtis Colizzi

Tester's Signature: Curtis Colizzi