

Shear Valve operation							
Owner Name:	GPM	Date: 2/28/25	Work Order #: 229919				
Facility Name:	GPM #25305	Facility ID#					
Address:	26395 SR 2 W	Testing Company: R. W. Mercer Co.	Kalamazoo 269-321-2280				
City, State, Zip Code:	South Bend IN 46619	Tester: Curtis Colizzi	Certification #: C35862				

Product Grade		REGULAR										
Dispensers Tested	Disp 1/2	Disp 3/4	Disp 5/6	Disp 7/8	Disp 9/10	Disp 11/12						
Is the shear valve rigidly anchored to the dispenser box frame or dispenser stand?	Yes	Yes	Yes	Yes	Yes	Yes						
Is the shear section positioned between 1/2" above or below the top surface of the dispenser island?	Yes	Yes	Yes	Yes	Yes	Yes						
Is the lever arm free to move?	Yes	Yes	Yes	Yes	Yes	Yes						
Does the lever arm snap shut the poppet valve?	Yes	Yes	Yes	Yes	Yes	Yes						
Can any product be dispensed when the shear valve is closed?	No	No	No	No	No	No						
Test Results	Pass	Pass	Pass	Pass	Pass	Pass						

Product Grade	PREMIUM										
Dispensers Tested	Disp 1/2	Disp 3/4	Disp 5/6	Disp 7/8	Disp 9/10	Disp 11/12					
s the shear valve rigidly anchored to the dispenser box frame or dispenser stand?	Yes	Yes	Yes	Yes	Yes	Yes					
s the shear section positioned between 1/2" above or below the top surface of the dispenser island?	Yes	Yes	Yes	Yes	Yes	Yes					
s the lever arm free to move?	Yes	Yes	Yes	Yes	Yes	Yes					
Does the lever arm snap shut the poppet valve?	Yes	Yes	Yes	Yes	Yes	Yes					
Can any product be dispensed when the shear valve is closed?	No	No	No	No	No	No					
Fest Results	Pass	Pass	Pass	Pass	Pass	Pass					

Product Grade	DIESEL											
Dispensers Tested	Disp 7/8	Disp 11/12										
Is the shear valve rigidly anchored to the dispenser box frame	Yes	Yes										
or dispenser stand?	res	Yes										
Is the shear section positioned between 1/2" above or below	Yes	Yes										
the top surface of the dispenser island?	res	res										
Is the lever arm free to move?	Yes	Yes										
Does the lever arm snap shut the poppet valve?	Yes	Yes										
Can any product be dispensed when the shear valve is closed?	No	No										
Test Results	Pass	Pass										
Comments:	"	•										
Comments:											_	

Product Grade							
Dispensers Tested							
Is the shear valve rigidly anchored to the dispenser box frame							
or dispenser stand?							
Is the shear section positioned between 1/2" above or below							
the top surface of the dispenser island?							
Is the lever arm free to move?							
Does the lever arm snap shut the poppet valve?							
Can any product be dispensed when the shear valve is closed?							
Test Results							
Comments:				-			

Tester's Name (print):	Curtis Colizzi	Tester's Signature:	Curtis Colizzi
rester's Name (print).	Curtis Conzer	rester's signature.	OVITOD OUVELLV